



# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

No.34, 1<sup>st</sup> Cross, Mohan Rao Colony,  
Krishnagiri - 635001.

Phone: 04343-233356

E-mail:jwakrishnagiri@gmail.com


### TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 48414-1	Report Issue Date :	15.02.2025	Page No : 01 of 01
Invoice Details:	222/Dt. 13.02.2025	ULR No	----	

Client Name & Address Contact No / Email.ID	: Eternal Light Public School , 244/1,Thiru.Ve.Ka.Nagar, Doddathimmanahalli, Rayakottai, Krishnagiri-63516.
Sample Name	: Water
Sample Number	: 48414
Sample Description	: BW Water
Sample Submitted by	: Eternal Light Public School
Location & Date	: Eternal Light Public School & 13.02.2025
Quantity of sample Received	: 2L
Sample Container	: Plastic - Good
Sample Condition on Receipt	: Good
Sample Received On	: 13.02.2025
Test Commenced on	: 13.02.2025
Test Completed on	: 14.02.2025
Environmental Condition	: 23.0°C – 27.0°C

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25 <sup>o</sup> C	-	IS 3025 Part 11-1983	7.57	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO <sub>3</sub>	mg/L	IS 3025 Part 21-2009	560	200	600
3	Total Alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025-Part 23-1986	412	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	182	250	1000
5	Sulphate as SO <sub>4</sub>	mg/L	IS 3025-Part 24-1986	128	200	400
6	Nitrate as NO <sub>3</sub>	mg/L	APHA 23rd Edition 2017- 4500 -NO <sub>3</sub> B	36	45	45
7	Fluoride as F	mg/L	APHA 23rd Edition 2017 - 4500- F-D	1.0	1.0	1.5

  
Authorised Signatory  
Junior Water Analyst  
DWTL Krishnagiri

#### Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

No.34, 1<sup>st</sup> Cross, Mohan Rao Colony,  
Krishnagiri - 635001.

Phone: 04343-233356

E-mail: jwakrishnagiri@gmail.com

### TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 48414-1	Report Issue Date :	15.02.2025	Page No : 01 of 01
Invoice Details:	222/Dt. 13.02.2025	ULR No	----	

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500:2012(RA:2019)	
8	Appearance	Physical observation	--	Clear	Clear	Clear
9	Colour	Physical observation	--	Colourless	Colourless	Colourless
10	Odour	IS 3025 part 5 : 1983	--	Agreeable	Agreeable	Agreeable
11	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0.6	1	5
12	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	1043	500	2000
13	Conductivity	APHA 23rd Edition 2017 - 2510 B	µS/cm	1491	-	-
14	P - Alkalinity	IS 3025-part 23-1983	mg/L	-	-	-
15	Calcium	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	134	75	200
16	Magnesium	APHA 23rd Edition 2017- 3500 Mg B	mg/L	54	30	100
17	Iron	APHA 23rd Edition 2017- 3500 Fe B	mg/L	0	0.3	1.0
18	Manganese	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	-	0.1	0.3
19	Ammonia	APHA 17th Edition- 1989- 4500 NH3C	mg/L	0.5	0.5	0.5
20	Nitrite as NO2	APHA 23rd Edition 2017- 4500 -NO2 B	mg/L	-	-	-
21	Total Phosphate as PO4	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0	-	-
22	Tidy's	APHA 23rd Edition 2017 - 4500 O - B	mg/L	-	-	-
23	Residual Chlorine	-	mg/L	0	0.2	1.0
24	Fecai Coliform CFU/100	IS/APHA	mg/L	0	0	0
25	Total Coliform CFU/100ML	IS/APHA	mg/L	0	0	0

Note : The above given sample is Potable to the drinking water specification as per IS 10500:2012(RA:2019) with respect to above tested parameters.

*[Handwritten Signature]*  
15.02.25

Authorised Signatory  
Junior Water Analyst  
DWTL Krishnagiri

#### Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated  
23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00125KGI16195

Issued Date : 24-11-2025

Organization Type : Educational Institutions

Expiry Date : 23-11-2026

Name of the Organization : ETERNAL LIGHT PUBLIC SCHOOL

Address : 244/1, T V K Nagar, Doddathimanahalli P. O, Rayakotta

I, JEREMY TAYLOR owner/manager of the ETERNAL LIGHT PUBLIC SCHOOL functioning as Educational Institutions located at Rayakottah in Krishnagiri district hereby declare that

- This Self-Declared Sanitation certificate is valid from 24-11-2025 to 23-11-2026 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 1200 people/pupils and has 15 urinals and 28 toilets which is proportionate to the number of users as per government norms.
- 6 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN00125KGI16195 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பாரகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00125KGI16195 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.